

**PRODUCER STATEMENT - DESIGN FOR THE ORIGINAL STONE VENEER
(EXTERNAL OR INTERNAL LANDSCAPING ONLY): AUCKLAND COUNCIL**

To: Original Stone Limited

In relation to: Original Stone Interior and Exterior Veneer System

In respect to: Performance requirements of Clauses B1, B2, F2 and E2 of the first schedule of the building regulations 1992

Verifications:

Compliance with the performance requirements of the first schedule of the building regulations 1992 has been verified on the basis of engineer reports prepared by King & Dawson Limited, the technical report provided by OPUS International Consultants and the testing performed by BEAL Limited (Reports TR120301 & TR120302). The compliance was endured through a series of standardised tests performed in accordance with AS/NZS 2908.2 and AS/NZS 4456.10, and testing performed to ensure the structural stability of the veneer system.


Documents:

All installation work must be carried out in accordance with the manufacture specifications "4272S-Summer Stone Veneer Cladding System" and the drawings dated November 2011. Note that the size and centre to centre spacing of timber studs must be verified as adequate for the actual wall height and the wall element fixing details specified. Additionally, the main structural system of the building should be designed in accordance with the relevant design standards to support the additional imposed dead load of the cladding system and a seismic analysis should be performed using the increased seismic weight of the building.

As a designer I have taken all reasonable steps to verify design assumptions. I am satisfied on reasonable grounds that in relation to the building work specified above, the provisions of the building code would be met if the building work were properly completed in accordance with the drawings, specifications and other documents according to which the building is proposed to be constructed.

Designer:

Dated: 5 March, 2012

A handwritten signature in black ink, appearing to be 'Kefa Morgan', with a long horizontal line extending to the right from the end of the signature.

Dr. Kefa Morgan

Qualification: CPEng (72824)

This Producer Statement is limited to applications of the Original Stone Interior and Exterior Veneer System within the Auckland Council boundaries for a period of two years expiring 1 March 2014.